

Results of environmental monitoring at each NPSs etc. (as of 9:00AM, May 30)

unit: μ Sv/h

Range of normal average value	Company	NPS	May 29, 2011													
			10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
0.016~0.133*	Hokkaido Electric Power Co.	Tomari NPS	0.032	0.032	0.032	0.035	0.032	0.032	0.032	0.032	0.032	0.031	0.031	0.031	0.032	0.031
0.024~0.060	Tohoku Electric Power Co.	Onagawa NPS	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22
0.012~0.060		Higashidori NPS	0.02	0.022	0.021	0.02	0.019	0.021	0.021	0.019	0.02	0.022	0.022	0.02	0.019	0.017
0.033~0.050	Tokyo Electric Power Co.	Fukushima Dai-ichi	(publicized in another place.)													
0.036~0.052		Fukushima Dai-ni														
0.011~0.159	Japan Atomic Power Co.	Kashiwazaki kariwa NPS	0.071	0.072	0.069	0.069	0.068	0.071	0.076	0.076	0.072	0.069	0.070	0.068	0.067	0.066
0.036~0.053		Tokai Dai-ni NPS	0.269	0.269	0.269	0.268	0.268	0.268	0.267	0.267	0.267	0.265	0.265	0.264	0.266	0.265
0.039~0.110		Tsuruga NPS	0.075	0.075	0.081	0.094	0.106	0.107	0.098	0.093	0.093	0.093	0.095	0.093	0.093	0.094
0.036~0.080	Chubu Electric Power Co.	Hamaoka NPS	0.040	0.041	0.040	0.041	0.041	0.041	0.041	0.040	0.039	0.039	0.039	0.039	0.040	0.040
0.0207~0.132	Hokuriku Electric Power Co.	Shika NPS	0.036	0.036	0.035	0.037	0.039	0.040	0.041	0.044	0.046	0.047	0.050	0.051	0.052	0.054
0.028~0.130	Chugoku Electric Power Co.	Shimane NPS	checking	checking	checking	checking	checking	checking	checking	checking	checking	checking	checking	checking	checking	checking
0.070~0.077	Kansai Electric Power Co.	Mihama NPS	0.075	0.073	0.076	0.081	0.081	0.081	0.080	0.078	0.077	0.077	0.078	0.080	0.083	0.092
0.045~0.047		Takahama NPS	0.062	0.063	0.067	0.058	0.075	0.069	0.067	0.070	0.075	0.072	0.078	0.081	0.083	0.071
0.036~0.040		Ooi NPS	0.051	0.056	0.052	0.053	0.066	0.062	0.057	0.060	0.051	0.057	0.055	0.059	0.055	0.059
0.011~0.080	Shikoku Electaic Power Co.	Ikata NPS	0.030	0.032	0.041	0.047	0.028	0.021	0.017	0.026	0.025	0.023	0.024	0.025	0.021	0.018
0.023~0.087	Kyushu Electric Power Co.	Genkai NPS	0.033	0.032	0.031	0.027	0.027	0.027	0.029	0.031	0.030	0.028	0.025	0.025	0.025	0.025
0.034~0.120		Sendai NPS	0.039	0.041	0.037	0.035	0.038	0.038	0.035	0.036	0.037	0.038	0.036	0.037	0.041	0.039
0.009~0.069	Japan Nuclear Fuel Limited	Japan Nuclear Fuel Reprocessing Plant	0.017	0.017	0.018	0.019	0.019	0.020	0.020	0.019	0.019	0.023	0.021	0.022	0.020	0.018
0.009~0.071		Japan Nuclear Fuel Plant Disposal	0.024	0.025	0.025	0.025	0.025	0.025	0.025	0.025	0.026	0.028	0.028	0.027	0.026	0.024

* The range of normal average value reported from the Hokkaido Electric Power Co. was changed to the value before the earthquake.

© Chubu Electric Power Co. reported that from 12:00, April 1st, the data did not include the contribution of cosmic rays.

Range of normal average value	Company	NPS	May 30, 2011									
			0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00
0.016~0.133*	Hokkaido Electric Power Co.	Tomari NPS	0.031	0.031	0.031	0.032	0.032	0.032	0.032	0.031	0.032	0.032
0.024~0.060	Onagawa NPS		0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22
0.012~0.060	Tohoku Electric Power Co.	Higashidori NPS	0.018	0.017	0.018	0.018	0.018	0.019	0.018	0.017	0.018	0.018
0.033~0.050	Tokyo Electric Power Co.	Fukushima Dai-ichi	(publicized in another place.)									
0.036~0.052		Fukushima Dai-ni										
0.011~0.159	Japan Atomic Power Co.	Kashiwazaki kariwa NPS	0.066	0.066	0.067	0.066	0.066	0.067	0.067	0.066	0.067	0.067
0.036~0.053		Tokai Dai-ni NPS	0.267	0.266	0.266	0.266	0.267	0.267	0.269	0.272	0.270	
0.039~0.110		Tsuruga NPS	0.095	0.096	0.095	0.087	0.093	0.082	0.086	0.084	0.077	0.073
0.036~0.080	Chubu Electric Power Co.	Hamaoka NPS	0.040	0.040	0.040	0.040	0.040	0.040	0.042	0.044	0.046	0.046
0.0207~0.132	Hokuriku Electric Power Co.	Shika NPS	0.057	0.058	0.053	0.039	0.036	0.046	0.040	0.036	0.035	0.035
0.028~0.130	Chugoku Electric Power Co.	Shimane NPS	checking	checking	checking	checking	checking	checking	checking	checking	checking	checking
0.070~0.077	Kansai Electric Power Co.	Mihama NPS	0.094	0.090	0.091	0.090	0.091	0.100	0.098	0.091	0.083	0.075
0.045~0.047		Takahama NPS	0.066	0.068	0.067	0.068	0.065	0.061	0.058	0.054	0.048	0.043
0.036~0.040		Ooi NPS	0.056	0.064	0.070	0.069	0.065	0.056	0.055	0.052	0.044	0.033
0.011~0.080	Shikoku Electric Power Co.	Ikata NPS	0.019	0.018	0.015	0.014	0.014	0.013	0.013	0.013	0.013	0.013
0.023~0.087	Kyushu Electric Power Co.	Genkai NPS	0.025	0.024	0.025	0.025	0.025	0.027	0.024	0.025	0.024	0.028
0.034~0.120		Sendai NPS	0.035	0.037	0.036	0.037	0.038	0.037	0.036	0.036	0.037	0.037
0.009~0.069	Japan Nuclear Fuel Limited	Japan Nuclear Fuel Reprocessing Plant	0.017	0.017	0.018	0.019	0.020	0.019	0.018	0.018	0.017	0.017
0.009~0.071		Japan Nuclear Fuel Plant Disposal	0.023	0.024	0.024	0.025	0.025	0.024	0.024	0.023	0.022	0.023

* The range of normal average value reported from the Hokkaido Electric Power Co. was changed to the value before the earthquake.

© Chubu Electric Power Co. reported that from 12:00, April 1st, the data did not include the contribution of cosmic rays.