

June 8, 2011
Nuclear and Industrial Safety Agency

Regarding Collection of Reports related to Improvements to Work Environment Inside the Reactor Building of Unit 2 at Fukushima Dai-ichi Nuclear Power Station, Tokyo Electric Power Co. Inc.

This is to inform the public that, to verify the validness of the emergency measures under Article 64, Paragraph 1 of the Act on the Regulation of Nuclear Source Materials, Nuclear Fuel Materials and Reactors (1957, Act No. 166), today (June 8), NISA requested Tokyo Electric Power Co. Inc.(TEPCO) to submit a report, as attached, pursuant to the provisions of Article 67, Paragraph 1 of the same act.

1. At Unit 2 of the Fukushima Dai-ichi Nuclear Power Station (NPS), TEPCO is planning to ventilate inside the buildings by leaving the double doors continuously open for the purpose of improving the environment of the reactor building, and connecting construction for the nitrogen injection and other measures, in order to implement calibration of water level gauges of the Reactor Pressure Vessel and the Primary Containment Vessel
2. By keeping the double doors continuously open, it can be considered that radioactive materials existing in the air inside the buildings will be

dispersed to the environment outside the reactors; accordingly, it is necessary to evaluate the impact in advance.

3. This is to inform the public that taking the above into consideration, NISA requested TEPCO to submit a report pursuant to the provisions of Article 67, Paragraph 1 of Act on the Regulation of Nuclear Source Materials, Nuclear Fuel Materials and Reactors, in the same way when the double doors of the reactor buildings for Unit 1 were left continuously open.

(Contact Person)

Mr. Toshihiro Bannai

Director, International Affairs Office,
NISA/METI

Phone: +81-(0)3-3501-1087

Ministry of Economy, Trade and Industry

06.06.2011 N No. 3

June 8, 2011

Tokyo Electric Power Co. Inc.
President Masataka Shimizu

Minister of Economy, Trade and Industry
Banri Kaieda

Regarding the Collection of Reports Related to the Improvement of the Work Environment inside the Reactor Building of Unit 2 at Fukushima Dai-ichi Nuclear Power Station

In order to verify the validness of the emergency measures under Article 64, Paragraph 1 of the Act on the Regulation of Nuclear Source Materials, Nuclear Fuel Materials and Reactors (1957, Act No. 166), the Ministry orders your company to, to submit a report regarding the below-specified items by June 15, 2011, pursuant to the provisions of Article 67, Paragraph 1 of the same act.

If there are grievances regarding this action, pursuant to the provisions of Article 6 of the Administrative Appeal Act (Act No. 160 of 1962), an administrative appeal may be made, in writing, to the Minister of Economy, Trade and Industry within 60 days from the date one day after the day on which your company became aware of the fact that this disposition was made. However, no administrative appeals may be made when a period of one year has elapsed from the date one day after the date of this disposition, even if it is within 60 days from the date one day after the day on which your company became aware of the fact that this disposition was made.

Following the decision regarding the aforementioned objection, an action for the revocation of this disposition may be filed against the State (represented by the Minister of Justice) as defendant, within six months from the date one day after the day on which your company became aware of

the fact that a decision was made in response to the aforementioned administrative appeal, pursuant to the provisions of Administrative Case Litigation Act (Act No. 139 of 1962). However, no action for the revocation of the disposition may be filed when a period of one year has elapsed from the date one day after the day on which the decision on the administrative appeal was made, even if it is within six months from the date one day after the day on which your company became aware of the fact that the decision on the administrative appeal was made.

Furthermore, an action for the revocation of the original administrative disposition may be filed without obtaining a decision on an administrative appeal, if the case falls under any of the following 1 to 3: 1. where no decision is made even after a period of three months has elapsed from the date one day after the day on which an administrative appeal was made; 2. where there is an urgent necessity in order to avoid any considerable damage that would be caused by the original administrative disposition, the execution of the original administrative disposition or the continuation of any subsequent procedure; 3. where there are other justifiable grounds not to obtain a decision on an administrative appeal.

Required Items

Following items related to the improvement of the work environment inside the reactor building of Unit 2 at Fukushima Dai-ichi Nuclear Power Station (NPS)

1. Results of evaluation based on whether or not alternative means exist regarding the operation details related to the ventilation of the reactor building of Unit 2 at Fukushima Dai-ichi NPS, the operation plan, as well as their necessity.
2. Results of evaluation for impact on the surrounding environment of the Fukushima Dai-ichi NPS including the release of radioactive materials during the operations related to the ventilation of the reactor building of Unit 2 at Fukushima Dai-ichi NPS as well as the predictions for the

disperse of said radioactive materials.

3. Monitoring method in order to evaluate properly the impact on the surrounding environment of the Fukushima Dai-ichi NPS when the radioactive materials are released if the operations in 2. are executed.
1. Method for managing workers' exposure for the construction, etc. to be executed after the ventilation of the reactor building of Unit 2 at Fukushima Dai-ichi NPS